

## EC - TYPE EXAMINATION CERTIFICATE

### Equipment or Protective System Intended for use in Potentially Explosive Atmospheres Directive 94/9/EC

- 3 EC - Type Examination Certificate Number: **Baseefa08ATEX0086X – Issue 7**
- 4 Equipment or Protective System: **HS-420 Series Accelerometer**
- 5 Manufacturer: **Hansford Sensors Limited**
- 6 Address: **Sands Industrial Estate, Bucks, HP12 4HJ**
- 7 This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- 8 Baseefa, Notified Body number 1180, in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.
- The examination and test results are recorded in confidential Report No's. See Certificate History
- 9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:  
**EN 60079-0:2012+A11:2013 EN 60079-11:2012**  
except in respect of those requirements listed at item 18 of the Schedule.
- 10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- 11 This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- 12 The marking of the equipment or protective system shall include the following :

⊕ II 1G Ex ia IIC T6 Ga (-40°C ≤ T<sub>a</sub> ≤ +60°C)

⊕ II 1D Ex ia IIIC T80°C IP65 Da (-40°C ≤ T<sub>a</sub> ≤ +60°C)

⊕ I M1 Ex ia I Ma (-40°C ≤ T<sub>a</sub> ≤ +60°C)

Baseefa Customer Reference No. **5943**

Project File No. **15/0448**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

### SGS Baseefa Limited

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601

e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN

  
R S SINCLAIR

GENERAL MANAGER

On behalf of SGS Baseefa Limited

## 13 Schedule

## 14 Certificate Number Baseefa08ATEX0086X – Issue 7

## 15 Description of Equipment or Protective System

The HS-420 Series Accelerometers are designed to measure velocity or acceleration by converting the signal generated by the compression of a piezo electric crystal by a given seismic mass and output a 4 to 20mA signal proportional to velocity or acceleration to the monitoring equipment.

The accelerometer comprises a piezo electric crystal connected to a signal conditioning board all contained within a stainless steel enclosure of various shapes measuring approximately 33cm<sup>3</sup>. The enclosure is a fully welded construction.

Electrical connections are made to the apparatus either via an IP65 rated connector or via an integral cable which is encapsulated in the end of the apparatus.

The Group II version of the apparatus (excluding cable) has the following terminal parameters:

$$\begin{aligned} U_i &= 28V \\ I_i &= 115mA \\ P_i &= 0.65W \end{aligned}$$

The HS-420IT or HS-422IT Accelerometer, with an integral temperature sensor and 25m of cable has the following terminal parameters for all four electrical connections considered as a single intrinsically safe circuit:

$$\begin{aligned} U_i &= 44V \\ I_i &= 117mA \\ P_i &= 0.722W \\ C_i &= 3nF \\ L_i/R_i &= 13nH/\Omega \end{aligned}$$

The Group I version of the apparatus (excluding cable) has the following terminal parameters:

$$\begin{aligned} U_i &= 16.5V \\ P_i &= 1.74W \end{aligned}$$

The apparatus must be powered from a power limited source such as an appropriately certified fuse assembly containing a  $\leq 62mA$  fuse, 1.74W (16.5V x 62mA x 1.7).

The Group I version of the apparatus (excluding cable) has the following alternative terminal parameters:

$$\begin{aligned} U_i &= 28V \\ I_i &= 115mA \\ P_i &= 0.65W \end{aligned}$$

The capacitance and inductance to resistance ratio of the different versions have the following parameters:

	Integral Cable or 2-Pin Mill Spec Connector with cable				4-Pin M12 Connector
	Polyurethane Cable	Silicone Cable	Armoured Cable	PUR Cable	Polyurethane Cable
$C_i$	= 160pF/m	= 370pF/m	= 290pF/m	= 884pF/m	= 120pF/m
$L_i/R_i$	= 8.32 $\mu$ H/ $\Omega$	= 15.4 $\mu$ H/ $\Omega$	= 15.4 $\mu$ H/ $\Omega$	= 6.1 $\mu$ H/ $\Omega$	= 11.7 $\mu$ H/ $\Omega$



**16 Report Number**

See Certificate History

**17 Specific Conditions of Use**

1. The free end of the cable on the integral cable version of the apparatus must be terminated in an appropriately certified dust proof enclosure

**18 Essential Health and Safety Requirements**

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

**19 Drawings and Documents**

New drawings submitted for this issue of certificate.

Number	Sheet	Issue	Date	Description
M06-008-F	1 to 5	F	12/06/15	General Arrangement and Product Information for Group I, Group II and Group III HS-420 & HS-422 Series Accelerometers

Current drawings also associated with this certificate.

Number	Sheet	Issue	Date	Description
M06-009-B	1 of 1	B	13/01/11	Zener Diode Arrangement HS-420 & HS-422 Series Accelerometer
M06-014-A	1 of 2	A	19.03.08	Din Rail Mounted Enclosure with a 62mA Safe-T-Fuse 259 Series F.U.W. HS-420M/HS422M Series Group I Accelerometers
M06-014-A	2 of 2	A	19.03.08	Inline Fuse with a 62mA Pico II 251 Series Fuse F.U.W. HS-420M/HS422M Series Group I Accelerometers
M06-020-C	1 to 4	C	30/08/12	General Arrangement and Product Information for Group I Fused HS-420 & HS-422 Series Accelerometer
M06-022-C	1 to 3 of 4	C	30/08/12	General Arrangement and Product Information for Group II HS-420IT & HS-422IT Series Accelerometer
M06-022-C	4 of 4	C	30/08/12	General Arrangement and Product Information for Group II and Group III HS-420IT & HS-422IT Series Accelerometer
HS420-IS	1 of 1	C	05.01.11	HS-420/HS-422 4-20mA Circuit
HS420M	1 of 1	C	14.01.11	HS-420M/HS-422M 4-20mA Circuit
HS420IT	1 of 1	D	14.01.11	HS-420IT/HS-422IT 4-20mA Circuit
P01-004	1 of 1	D	05.01.11	4-20mA PCB Track Layout
P02-004	1 of 1	D	05.01.11	4-20mA PCB Component Layout
P01-012	1 of 1	A	03.03.08	HS420I PCB for M12 Connector
P02-012	1 of 1	A	27.02.08	HS420I PCB Connector
P01-026	1 of 1	A	19.05.08	HS420M Connection PCB for M12 Connector
P02-026	1 of 1	A	19.05.08	HS420M Connection PCB
P01-027	1 of 1	B	09.09.08	HS420IT Connection PCB for M12 Connector
P02-027	1 of 1	B	09.09.08	HS420IT Connection PCB

These drawings are associated and held with IECEx BAS 08.0034X

**20 Certificate History**

Certificate No.	Date	Comments
Baseefa08ATEX0086X	10 April 2008	The release of the prime certificate. The associated test and assessment is documented in Test Report GB/BAS/ExTR08.0059/00.

Certificate No.	Date	Comments
Baseefa08ATEX0086/1	1 July 2008	<p>To permit the introduction of a new mining version complete with integral fuse identified as: HS-420MFxxxzyzz or HS-422MFxxxzyzz.</p> <p>To permit minor non-electrical changes that do not affect the original assessment.</p> <p>Intrinsic safety is not affected. The associated test and assessment is documented in Test Report GB/BAS/ExTR08.0112/00.</p>
Baseefa08ATEX0086/2	18 September 2008	<p>To permit the introduction the HS-420IT or HS-422IT Accelerometer, with an integral temperature sensor, 25m of cable and associated electrical connections.</p> <p>Intrinsic safety is not affected. The associated test and assessment is documented in Test Report GB/BAS/ExTR08.0181/00.</p>
Baseefa08ATEX0086/3	4 February 2009	<p>To permit minor mechanical changes that do not affect the original assessment.</p> <p>Intrinsic safety is not affected. The associated test and assessment is documented in Test Report GB/BAS/ExTR09.0014/00.</p>
Baseefa08ATEX0086/4	24 January 2011	<p>To permit minor electrical changes that do not affect the original assessment.</p> <p>To permit minor marking changes that do not affect the original assessment.</p> <p>Clarification of components not fitted to PCB added to report.</p> <p>Intrinsic safety is not affected. The associated test and assessment is documented in Test Report GB/BAS/ExTR11.0013/00.</p>
Baseefa08ATEX0086/5	2 February 2012	<p>To permit the HS-420M series of the equipment (not the HS-420MF series) to be marked with alternative terminal parameters.</p> <p>Intrinsic safety is not affected. The associated test and assessment is documented in Test Report GB/BAS/ExTR12.0005/00.</p>
Baseefa08ATEX0086/6	10 October 2012	<p>To confirm that the equipment covered by this certificate also meets the requirements of EN60079-0: 2012 (IEC60079-0: 2011, Edition 6) and EN60079-11: 2012 (IEC60079-11: 2011, Edition 6) as supported by GB/BAS/ExTR12.0254/00 held on technical file IECEx BAS 07.0035X.</p>
Baseefa08ATEX0086X Issue 7	17 June 2015	<p>This issue of the certificate incorporates previously issued primary &amp; supplementary certificates into one certificate and permits the following changes:</p> <p>To permit the use of an alternative PUR cable.</p> <p>To permit the use of an alternative 2-Pin connector.</p> <p>Intrinsic safety is not affected. The associated test and assessment is documented in Test Report GB/BAS/ExTR15.0175/00.</p>
For drawings applicable to each issue, see original of that issue.		