



Table 1: Cable Parameters For Additional Cable Lengths		
Accelerometer With Integral Cable Length ≤ 10m		
Group	Capacitance µF	L/R Ratio µH/Ω
IIC	0.079	56
IIB	0.245	168
IIA	0.660	448
Accelerometer With Integral Cable Length ≤ 50m		
Group	Capacitance µF	L/R Ratio µH/Ω
IIC	0.064	56
IIB	0.230	168
IIA	0.645	448
Accelerometer With Integral Cable Length ≤ 100m		
Group	Capacitance µF	L/R Ratio µH/Ω
IIC	0.046	56
IIB	0.212	168
IIA	0.627	448



Baseefa
Certification
Schedule
Drawing

baseefa 08 Y 0087

Handwritten signature

Hansford Sensors Ltd

HS-4201 & HS-4221
Accelerometer System
Baseefa08Y0087
Ex ia IIC T6 (-40°C ≤ Ta ≤ +60°C)

- Notes:**
1. The capacitance and Inductance, or Inductance - to - resistance ratio (L/R) of hazardous area cable, must not exceed the values shown in Table 1.
 2. The cable from the accelerometer to the junction box must not be installed in a high velocity dust laden atmosphere.
 3. Any shunt zener diode safety barrier certified by an ec approved body to [EEEx ia] IIC having the following output parameters: Uo = 28V dc, Io = 93mA dc, Po = 0.65W. e.g. MTL7787 to BAS01ATEX7217 or Pepperl + Fuchs Z787 to BAS01ATEX7005.
 4. The installer is to perform a risk assessment in accordance with clause 10 of EN 60079-25 and install lightning protection arrestors as deemed necessary.

Rev No	DRF No	Date Drg	Drg By	Appd By
A	Release	10/03/08	MJS	CMH

Material: **N/A**

Tolerances Unless Stated

0 or 0.0 ±0.5
0.00 ±0.15
Angle ±5°

1.6/ Finish All Over
Threads g6 H6

Hansford Sensors
Excellence in Vibration Monitoring

Hansford Sensors Ltd
Saunderton Business Park
Haw Lane
Saunderton
Bucks HP14 4JE

Do Not Scale

All Dimensions In mm Unless
Otherwise Stated

If In Doubt - Ask!

Description: **System Connections
For HS-4201 & HS-4221 Group II
Accelerometers With Non Armoured
Silicone Cable F.U.W. Zener Barrier**

Drawing No: **M06-012-A**

Scale: **NTS**
Sheet: **2 of 2**

Form Number:
QF024 Issue 1