

IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:

IECEx BAS 08.0034X

Issue No: 10 Certificate history:

Page 1 of 4

Status:

Current

Issue No. 10 (2017-05-16)

Date of Issue:

Issue No. 9 (2015-06-17)

2017-05-16

Issue No. 8 (2013-01-15) Issue No. 7 (2012-10-12)

Applicant:

Hansford Sensors Limited

Issue No. 6 (2012-02-02)

Artisan

Issue No. 5 (2011-01-24)

Hillbottom Road

Issue No. 4 (2009-11-30)

Sands Industrial Estate

Issue No. 3 (2009-02-05)

Bucks HP12 4HJ Issue No. 2 (2008-09-18)

United Kingdom

Issue No. 1 (2008-07-01) Issue No. 0 (2008-04-12)

Equipment:

HS-420 Series Accelerometer

Optional accessory:

Fuse Box

Type of Protection:

Intrinsic Safety, gas and dust

Marking:

Ex ia I Ma (-40°C ≤ Ta ≤ +60°C)

Ex ia IIC T6 Ga (-40°C ≤ Ta ≤ +60°C)

Ex ia III C T80°C IP65 Da (-40°C ≤ Ta ≤ +60°C)

Approved for issue on behalf of the IECEx

RS Sinclair PP DIREAVILES

Position:

Technical Manager

Signature:

(for printed version)

Certification Body:

Date:

- 1. This certificate and schedule may only be reproduced in full.
- 2. This certificate is not transferable and remains the property of the issuing body.
- 3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

Baseefa (2001) Ltd. Rockhead Business Park Staden Lane **Buxton** Derbyshire **SK17 9RZ United Kingdom**





IECEx Certificate of Conformity

Certificate No:

IECEx BAS 08.0034X

Issue No: 10

Date of Issue:

2017-05-16

Page 2 of 4

Manufacturer:

Hansford Sensors Limited

Artisan

Hillbottom Road Sands Industrial Estate

Bucks HP12 4HJ **United Kingdom**

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2011

Explosive atmospheres - Part 0: General requirements

Edition:6.0

IEC 60079-11: 2011

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition:6.0

This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

GB/BAS/ExTR08.0059/00

GB/BAS/ExTR08.0112/00

GB/BAS/ExTR08.0181/00

GB/BAS/ExTR09.0014/00 GB/BAS/ExTR12.0254/00 GB/BAS/ExTR11.0013/00 GB/BAS/ExTR15.0175/00 GB/BAS/ExTR12.0005/00

Quality Assessment Report:

GB/BAS/QAR07.0040/06



IECEx Certificate of Conformity

Certificate No:

IECEx BAS 08.0034X

Issue No: 10

Date of Issue:

2017-05-16

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The HS-420 Series Accelerometers are designed to measure velocity or acceleration by converting the signal generated by the compression of a piezo electric crystal by a given seismic mass and output a 4 to 20mA signal proportional to velocity or acceleration to the monitoring equipment.

The accelerometer comprises a piezo electric crystal connected to a signal conditioning board all contained within a stainless steel enclosure of various shapes measuring approximately 33cm³. The enclosure is a fully welded construction.

Electrical connections are made to the apparatus either via an IP65 rated connector or via an integral cable which is encapsulated in the end of the apparatus.

For terminal parameters see Annex.

SPECIFIC CONDITIONS OF USE: YES as shown below:

1. The free end of the cable on the integral cable version of the apparatus must be terminated in an appropriately certified dust proof enclosure.



IECEx Certificate of Conformity

Certificate No:

IECEx BAS 08.0034X

Issue No: 10

Date of Issue:

2017-05-16

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Variation 8.1

Addition of Ci & Li within the entity parameter information detailed in the Annex.

ExTR: None

File Reference: 17/0352

Annex:

IECEx BAS 08.0034X Annex Issue 3.pdf

SGS Baseefa Limited

Rockhead Business Park Staden lane, Buxton, Derbyshire **SK17 9RZ United Kingdom**



ANNEX to IECEx BAS 08.0034X

Issue No. 3

Date: 16 May 2017

The Group II version of the apparatus (excluding cable) has the following terminal parameters:

 $U_i = 28V$ $I_i = 115mA$

 $L_i = 0$

 $P_i = 0.65W$

The HS-420IT or HS-422IT Accelerometer, with an integral temperature sensor and 25m of cable has the following terminal parameters for all four electrical connections considered as a single intrinsically safe circuit:

 $U_i = 44V$

 $C_i = 3nF$

 $I_i = 117mA$

 $L_i/R_i = 13nH/\Omega$

 $P_i = 0.722W$

The Group I version of the apparatus (excluding cable) has the following terminal parameters:

 $U_i = 16.5V$

 $P_i = 1.74W$

 $C_i = 0$ $L_i = 0$

The apparatus must be powered from a power limited source such as an appropriately certified fuse assembly containing a ≤62mA fuse, 1.74W (16.5V x 62mA x 1.7).

The Group I version of the apparatus (excluding cable) has the following alternative terminal parameters:

 $U_i = 28V$

 $C_i = 0$

 $I_i = 115mA$

 $L_i = 0$

 $P_i = 0.65W$

The capacitance and inductance to resistance ratio of the different versions have the following parameters:

	Integral Cable or 2-Pin Mill Spec Connector with cable				4-Pin M12 Connector
	Polyurethane	Silicone	Armoured	PUR	Polyurethane
	Cable	Cable	Cable	Cable	Cable
Ci	= 160pF/m	= 370pF/m	= 290pF/m	= 884pF/m	= 120pF/m
Li	= 0.72μH/m	= 0.5μH/m	= 0.5µH/m	= 0.6µH/m	= 0.7μH/m
L _i /R _i	$= 8.32 \mu H/\Omega$	$= 15.4 \mu H/Ω$	$= 15.4 \mu H/Ω$	$= 6.1 \mu H/Ω$	= 11.7μH/Ω