



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx BAS 22.0041X	Page 1 of 3	<u>Certificate history:</u>
Status:	Current	Issue No: 0	
Date of Issue:	2022-10-05		
Applicant:	Hansford Sensors Limited Artisan Hillbottom Road Sands Industrial Estate Bucks HP12 4HJ United Kingdom		
Equipment:	HS-107 Series Accelerometer		
Optional accessory:			
Type of Protection:	Intrinsic Safety		
Marking:	Ex ia IIC T4 Ga (-55°C ≤ Ta ≤ +110°C) Ex ia IIIC T ₂₀₀ 130°C IP65 Da (-55°C ≤ Ta ≤ +110°C) Ex ia IIC T6 Ga (-55°C ≤ Ta ≤ +60°C) Ex ia IIIC T ₂₀₀ 80°C IP65 Da (-55°C ≤ Ta ≤ +60°C) Ex ia I Ma (-55°C ≤ Ta ≤ +110°C)		

Approved for issue on behalf of the IECEx
Certification Body:

Mr R S Sinclair

Position:

Technical Manager

Signature:
(for printed version)

Date:
(for printed version)

5/10/2022

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

SGS Baseefa Limited
Rockhead Business Park
Staden Lane
Buxton, Derbyshire, SK17 9RZ
United Kingdom





IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 22.0041X**

Page 2 of 3

Date of issue: 2022-10-05

Issue No: 0

Manufacturer: **Hansford Sensors Limited**
Artisan
Hillbottom Road
Sands Industrial Estate
Bucks
HP12 4HJ
United Kingdom

Manufacturing locations: **Hansford Sensors Limited**
Artisan
Hillbottom Road
Sands Industrial Estate
Bucks
HP12 4HJ
United Kingdom

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

GB/BAS/ExTR22.0149/00

Quality Assessment Report:

GB/BAS/QAR07.0040/10



IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 22.0041X**

Page 3 of 3

Date of issue: 2022-10-05

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The HS-107 Series Accelerometer is designed to measure acceleration, shock or vibration by converting the signal generated by the compression of a piezo electric crystal by a given seismic mass and outputting a broadband ac signal to the monitoring equipment.

The accelerometer comprises a piezo electric crystal connected to a signal conditioning board, all contained within a stainless steel enclosure of various shapes measuring approximately 25cm³. The enclosure is a fully welded construction.

Electrical connections are made to the apparatus either via an IP65 rated connector or via an integral cable which is encapsulated in the end of the apparatus.

The apparatus has the following terminal parameters:

Connector only	of Cable	10m Cable	92m of Cable
Ui = 28V	Ui = 28V	Ui = 28V	
Ii = 93mA	Ii = 93mA	Ii = 93mA	
Pi = 0.65W	Pi = 0.65W	Pi = 0.65W	
Ci = 1.0nF	Ci = 9.9nF	Ci = 83nF	
Li = zero	Li = 7μH or Li/Ri = 15.4mH/ Ω	Li/Ri = 15.4mH/Ω	

SPECIFIC CONDITIONS OF USE: YES as shown below:

1. The Ci of non-fused versions of the equipment (HS-107Mxxxxxxx and HS-107MSxxxxxxx) when fitted with 92m of cable increases from 9.9nF to 83nF. The fused versions when fitted with 92m of cable have Ci = 41nF.
2. The free end of the cable on the integral cable version of the apparatus must be terminated in an appropriately certified dust proof enclosure when dust protection is required.